

## STANDARD INFORMATION

**Standard:** UL 414

**Standard ID:** Metered Sockets [UL 414:2025 Ed.10+R:06May2026]

**Previous Standard ID:** Metered Sockets [UL 414:2025 Ed.10]

## EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

**Effective Date:** **September 9, 2028**

## IMPACT, OVERVIEW, AND ACTION REQUIRED

**Impact Statement:** Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

**Overview of Changes:** Revisions to removable housing member requirements. Specific details of new/revised requirements are found in table below.

***Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.***



## STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
Annex B	Info	<b>METER SOCKET ADAPTERS FOR USE WITH DISTRIBUTED GENERATION EQUIPMENT</b>
B14	Info	<b>Markings</b> <i>New clause added;</i>
B14.18		Assemblies with distributed generation equipment connections through a mating connection which are not interlocked to prevent connecting or disconnecting of the connectors under load in accordance with B7.1.8 shall be marked with the following or equivalent: "WARNING: Risk of Electric Shock. Disconnect all sources prior to removing this module." This marking shall be located on the exterior surface of the removable housing where it will be visible to persons while installing or servicing the meter socket adapter.
Annex C	Info	<b>METER SOCKET ADAPTERS WITH BRANCH CIRCUIT CONNECTIONS</b>
C7	Info	<b>Wiring Connections</b>
C7.1	Info	<b>External connections to power circuits</b> <i>New clause added;</i>
C7.1.10		A separate compartment in accordance with the Exception to C7.1.3 may be provided as a separate enclosure connected by flexible conduit not longer than 6 feet (1.83 m). <i>New clause added;</i>
C7.1.11		When external circuits are intended to be connected directly to the meter socket adapter through mating connectors, a disconnecting means shall be provided to isolate the utility source from the mating connectors prior to connection or disconnection. The disconnecting means shall be interlocked with the connectors to prevent connecting or disconnecting of the connectors unless the disconnecting means is open. Interlocking is not required if marked in accordance with C14.13. <i>New clause added;</i>
C7.1.12		Mating connections in C7.1.11 shall have provision for the application of a seal or lock by the serving utility. <i>New clause added;</i>
C7.1.13		When mating connections are provided in accordance with C7.1.11, live parts shall be located to prevent inadvertent contact by persons while installing or servicing the meter socket adapter.