

STANDARD INFORMATION

Standard: UL 651

Standard ID: Schedule 40, 80, Type EB and A Rigid PVC Conduit and Fittings [UL 651:2011 Ed.8+R:09Jan2026]

Previous Standard ID: Schedule 40, 80, Type EB and A Rigid PVC Conduit and Fittings [UL 651:2011 Ed.8+R:10May2022]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **January 9, 2028**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes: Flammability Test for Fittings. Specific details of new/revised requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined-out below.</i>
7	Info	Rigid PVC Conduit Fittings
7.7	Info	All types
7.2.2	Info	Flammability test
		When tested as described in 7.2.2.2:
7.2.2.1		a) A fitting shall not continue to flame for more than 5 seconds after the third application of the test flame; b) Flaming particles or drops shall not fall from the fitting during or after any application of the test flame; and c) The fitting shall not be entirely consumed <u>reduced to a mass of material that can no longer perform the intended function of that fitting during or after any application of the test flame.</u>